

Sunnyslope County Water District

Water & Wastewater Committee

A G E N D A

Date: November 29, 2012

Time: 2:30 p.m.

Committee Members: Danny Villalon – Dave Clapham

Staff Members: Ken Girouard – Don Ridenhour

Topics:

1. Review Ridgemark Wastewater Treatment Plant Change Orders 6 through 12 totaling \$13,979.60.
 - ◆ Change Order #06 – conduit & purge system solenoid valves (\$2,093.51)
 - ◆ Change Order #07 – access openings for level sensors to effluent basin (\$1,201.31)
 - ◆ Change Order #08 – handrail modifications to access mixers (\$5,280.88)
 - ◆ Change Order #09 – increase conduit and wire size to existing Pond 6 lift station (\$1,756.98)
 - ◆ Change Order #10 – add additional utility wash down system to dump station pit (\$1,769.79)
 - ◆ Change Order #11 – install District’s temporary 250 KW generator due to delivery delays for the permanent standby generator (\$1,374.63)
 - ◆ Change Order #12 – add door closer to Operation Building Sample Room (\$502.50)

2. Hollister Urban Area Water and Wastewater Master Plan
 - ◆ Schedule Update
 - ◆ Interagency Agreements Update

Date & Time Agenda Posted: November 21, 2012 at 10:30 a.m.